



February 28, 2020

Chief Administrative Officer
Corporation Township of Adjala-Tosorontio
7855 Sideroad 30, RR #1
Alliston, ON
L9R 1V1

Re: Safe Drinking Water Act, O.Reg. 170/03 Schedule 22 Summary Report for Hockley DWS

Dear, CAO:

Attached is the 2019 Summary Report for the Hockley Drinking Water System (DWS). This report has been completed based on the information in our records and in accordance with Schedule 22 of O. Reg. 170/03, under the Safe Drinking Water Act, which requires a Summary Report to be prepared no later than March 31st of each year for the preceding calendar year. This report covers the period of January 1, 2019 to December 31, 2019.

Please remember that any Orders that the Town has received directly from the Ministry of the Environment, Conservation and Parks (MECP) should be reviewed. If there is a non-compliance with the Order, we recommend that the information be added to this report, if not already. After your review and inclusion of any additional information, this Summary Report is to be provided to the members of the Municipal Council. Please ensure its distribution to the Council Members and please provide proof of their review.

We emailed a copy of the 2019 Annual Report for the Hockley DWS to your office on February 28, 2020. The Annual Report must cover the period from January 1 to December 31 in a year and must be prepared in accordance with Section 11 of O. Reg 170/03 and submitted no later than February 28 of the following year.

Section 12 of O. Reg. 170/03 requires both the Summary Report and the Annual Report to be made available for inspection by any member of the public at the office of the municipality or at a location that is reasonably convenient to the users of the water system, as indicated in the Section 11 Annual Report, during normal business hours and without charge.

Please let me know if there are any questions or comments concerning the Summary and/or Annual Report(s).

Thanks,

Colin Smith

*Process Compliance Technician | Ontario Clean Water Agency
North Simcoe Hub | Georgian Highlands Region
30 Woodland Drive, Wasaga Beach, ON L9Z 2V4
Office 705-429-2525 Ext: 24 | Cell 705.623.2390 | csmith4@ocwa.com*

SUMMARY REPORT

ONTARIO REGULATION 170/03
SCHEDULE 22

HOCKLEY DRINKING WATER SYSTEM



FOR THE PERIOD:
JANUARY 1, 2019 – DECEMBER 31, 2019

*Prepared for the Corporation of the Township of Adjala-Tosorontio
by the Ontario Clean Water Agency*

SCHEDULE 22
SUMMARY REPORTS FOR MUNICIPALITIES

Municipal: Large Residential
Small Residential

Application

22-1. This Schedule applies to the following drinking water systems:

1. Large municipal residential systems.
2. Small municipal residential systems.

Report

22-2. (1) The owner of a drinking water system shall ensure that, not later than March 31 of each year after 2003, a report is prepared in accordance with subsections (2) and (3) for the preceding calendar year and is given to,

- (a) in the case of a drinking water system owned by a municipality, the members of the municipal council;
- (b) in the case of a drinking water system owned by a municipal service board established under section 195 of the *Municipal Act, 2001*, the members of the municipal service board; or
- (c) in the case of a drinking water system owned by a corporation, the board of directors of the corporation.

(2) The report must,

- (a) list the requirements of the Act, the regulations, the system's approval, drinking water works permit, municipal drinking water licence, and any orders applicable to the system that were not met at any time during the period covered by the report; and
- (b) for each requirement referred to in clause (a) that was not met, specify the duration of the failure and the measures that were taken to correct the failure.

(3) The report must also include the following information for the purpose of enabling the owner of the system to assess the capability of the system to meet existing and planned uses of the system:

1. A summary of the quantities and flow rates of the water supplied during the period covered by the report, including monthly average and maximum daily flows.
2. A comparison of the summary referred to in paragraph 1 to the rated capacity and flow rates approved in the system's approval, drinking water works permit or municipal drinking water licence, or if the system is receiving all of its water from another system under an agreement pursuant to subsection 5 (4), to the flow rates specified in the written agreement.

(4) If a report is prepared under subsection (1) for a system that supplies water to a municipality under the terms of a contract, the owner of the system shall give a copy of the report to the municipality by March 31.

(5) Revoked: O. Reg. 253/05, s. 18.

Ontario Regulation 170/03: Drinking Water Systems

Schedule 22 Summary Report

JANUARY 01, 2019 – DECEMBER 31, 2019

DRINKING-WATER SYSTEM NAME:	HOCKLEY DRINKING WATER SYSTEM
DRINKING-WATER SYSTEM NUMBER:	220005036
DRINKING-WATER SYSTEM CATEGORY:	SMALL MUNICIPAL RESIDENTIAL
MUNICIPAL DRINKING WATER LICENCE #:	097-103, issued May 13, 2016
DRINKING-WATER WORKS PERMIT #:	097-203, issued May 13, 2016
PERMIT TO TAKE WATER #:	4342-8F2REZ

REPORT

This report is a summary of water quantity data for the Hockley Drinking Water System (DWS) in the Township of Adjala-Tosorontio written in accordance with Schedule 22 of Ontario's Drinking Water Systems Regulation for the reporting period of January 1, 2019 to December 31, 2019. This report was prepared by the Ontario Clean Water Agency on behalf of the Corporation of the Township of Adjala-Tosorontio.

ISSUES OF NON-COMPLIANCE

The following outlines any instances when the DWS failed to meet the requirements of the Act, Regulations, System Approval(s) and any Order during this reporting period and the measures taken to correct each failure.

Not Applicable for Reporting Period

Please refer to the Section 11 Annual Report for the Hockley DWS for information regarding Adverse Water Quality Incident(s) that may have occurred during the reporting period.

SYSTEM PERFORMANCE

The following table (Table 1) summarizes the quantities and flow rates of the raw water taken and treated water supplied during the period covered by this report, including monthly average and maximum day flows, and daily instantaneous peak flow rates, as well as a comparison with the maximum daily volume and flow rates specified in the system approval:

Table 1: Hockley DWS – Raw Water (RW) Summary for Reporting Period

Description	Well 1
Maximum Allowable Daily Volume (m ³ /day)*	90.0
Maximum Allowable Flow Rate (L/s)**	2.3
Average Daily Flow (m ³ /day)	9.36
Percentage of Maximum Daily Volume*	10.4
Maximum Daily Flow (m ³ /day)	100.43
Percentage of Maximum Daily Volume*	111.6
Average Flow Rate (L/s)	2.08
Percentage of Maximum Allowable Flow Rate**	90.4
Maximum Instantaneous Peak Flow Rate (L/s)	2.15
Percentage of Maximum Allowable Flow Rate**	93.5
Total Annual Volume (m ³)	3423.83

Ontario Regulation 170/03: Drinking Water Systems

Schedule 22 Summary Report

JANUARY 01, 2019 – DECEMBER 31, 2019

**As specified in the Permit to Take Water, where the “maximum daily volume” is the “Maximum Taken per Day” per well expressed in litres per day and stipulates a “Total Taking” of 90.0 m³/day*

***As specified in the Permit to Take Water, where the “maximum flow rate” is the Maximum Taken per Minute” per well expressed in litres per minute.*

Table 2: Hockley DWS – Treated Water (TW) Summary for Reporting Period

Description	TW
Rated Capacity (m ³ /day)*	199.0
Average Daily Flow (m ³ /day)	9.36
Percentage of Rated Capacity*	4.7
Maximum Daily Flow (m ³ /day)	100.43
Percentage of Rated Capacity*	50.5

**As specified in the Municipal Drinking Water Licence, where the “rated capacity” is the “the maximum daily volume of treated water that flows from the treatment subsystem to the distribution system,” expressed in cubic metres per day.*

A review of flow information for the period of January 1, 2019 to December 31, 2019 indicates that the maximum daily volume specified in the PTTW was exceeded on December 4th, 2019 at the well. The drinking water system did not exceed the MDWL Rated Capacity for treated water that flows from the treatment subsystem to the distribution system.

The following table (Table 2) outlines a more detailed flow summary for the Well.

Table 2: Hockley DWS - Facility Flow Summary for Raw Water Source Well 1

Month	Monthly Flow Total (m ³ /month)	Daily Flow Average (m ³ /day)	Daily Flow Maximum (m ³ /day)	Daily Average Flow Rate (L/sec)	Daily Peak Flow Rate (L/sec)	Number of Days of Water Taking
Jan	237.67	7.67	10.11	2.077	2.15	31
Feb	206.84	7.39	11.55	2.064	2.15	28
Mar	248.06	8.00	13.13	2.059	2.15	31
Apr	217.27	7.24	10.82	2.239	2.14	30
May	243.78	7.86	10.80	2.046	2.14	31
Jun	341.34	11.38	26.52	2.044	2.14	30
Jul	382.45	12.34	23.67	2.112	2.14	31
Aug	331.24	10.69	18.18	2.149	2.13	31
Sep	266.68	8.89	13.49	2.069	2.14	30
Oct	243.91	7.87	13.41	2.065	2.13	31
Nov	238.55	7.95	13.02	2.035	2.13	30
Dec	466.04	15.03	100.43	2.039	2.13	31
Total	3423.83	-	-	-	-	365
Avg.	-	9.36	-	2.083	-	-
Max.	-	-	100.43	-	2.15	-