

# ANNUAL REPORT

ONTARIO REGULATION 170/03  
SECTION 11

## HOCKLEY DRINKING WATER SYSTEM



FOR THE PERIOD:  
JANUARY 1, 2019 – DECEMBER 31, 2019

*Prepared for the Corporation of the Township of Adjala-Tosorontio  
by the Ontario Clean Water Agency*



<b>Drinking-Water System Number:</b>	<b>220005036</b>
<b>Drinking-Water System Name:</b>	<b>Hockley Drinking Water System</b>
<b>Drinking-Water System Owner:</b>	The Corporation of the Township of Adjala-Tosorontio
<b>Drinking-Water System Category:</b>	Small Municipal Residential
<b>Period being reported:</b>	<b>January 1, 2019 to December 31, 2019</b>

**Does your Drinking-Water System serve more than 10,000 people?**

No

**Is your annual report available to the public at no charge on a web site on the Internet?**

Yes

**Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.**

Summary Report is available for inspection at the Township of Adjala-Tosorontio Municipal Office at 7855 Side Road 30, Alliston, ON or on the following website: <http://www.adjtos.ca>

**List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:**

<b>Drinking Water System Name</b>	<b>Drinking Water System Number</b>
Not applicable	Not applicable

**Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?**

Not Applicable

**Indicate how you notified system users that your annual report is available, and is free of charge.**

- Public access/notice via the web**
- Public access/notice via Government Office**
- Public access/notice via a newspaper**
- Public access/notice via Public Request**
- Public access/notice via a Public Library**
- Public access/notice via other method**

**Description of Drinking-Water System:**

The Hockley water system is classified as a Small Municipal Residential water system with 14 services. Water is supplied via one municipal well and pumphouse. Inspections and maintenance duties are conducted by Ontario Clean Water Agency staff on a regular basis to maintain compliance with Ontario Regulation 170/03 to ensure that Hockley's water supply is safe to drink.

**List of water treatment chemicals used during the reporting period:**

- Sodium Hypochlorite 12% Solution NSF, Primary Disinfection

**Significant expenses incurred to:**

- Install required equipment
- Purchase required equipment
- Repair required equipment
- Replace required equipment

**Description of significant expenses incurred:**

1. Purchased a new pressure tank
2. Repaired chemical dosing pumps
3. Replaced the alarm dialer

**Details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre:**

Incident Date (yyyy/mm/dd)	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date (yyyy/mm/dd)
Not Applicable for Reporting Period					

**Table 1: Microbiological testing done under the Schedule 11 of Regulation 170/03 during this reporting period.**

Location	Number of Samples	Range of E. Coli or Fecal Results		Range of Total Coliform Results		Number of HPC Samples	Range of HPC Samples	
		Min	Max	Min	Max		Min	Max
Raw - RW1	12	0	0	0	0	N/A	N/A	N/A
Distribution - DW	27	0	0	0	0	27	0	3

**Table 2: Operational testing done under Schedule 7 of Regulation 170/03 during the period covered by this Annual Report.**

Location & Test	Number of Samples	Range of Results	
		Minimum	Maximum
Turbidity, Raw (Grab) [NTU]	12	0.21	1.5
Free Chlorine Residual, Treated (Continuous) [mg/L]	8760	0.73	5
Free Chlorine Residual, Treated (Grab) [mg/L]	168	1.29	5.1
Total Chlorine Residual, Treated (Grab) [mg/L]	168	1.34	6.3
Free Chlorine Residual, Distribution (Grab) [mg/L]	106	1.26	4.8

Note: The number of samples used for a continuous monitoring unit is 8760.

**Table 3: Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.**

Date of Legal Instrument Issued	Parameter	Date Sampled	Result	Unit of Measure
Not Applicable				

**Table 4: Summary of Inorganic parameters tested during this reporting period or the most recent sample results**

Parameter	Sample Date (yyyy/mm/dd)	Sample Result	Maximum Allowable Concentration (MAC)	Number of Exceedances	
				MAC	½ MAC
Antimony: Sb (µg/L) - TW	2018/01/17	<MDL 0.02	6.0	No	No
Arsenic: As (µg/L) - TW	2018/01/17	2.3	10.0	No	No
Barium: Ba (µg/L) - TW	2018/01/17	134.0	1000.0	No	No
Boron: B (µg/L) - TW	2018/01/17	33.0	5000.0	No	No
Cadmium: Cd (µg/L) - TW	2018/01/17	<MDL 0.003	5.0	No	No
Chromium: Cr (µg/L) - TW	2018/01/17	0.06	50.0	No	No
Mercury: Hg (µg/L) - TW	2018/01/17	<MDL 0.01	1.0	No	No
Selenium: Se (µg/L) - TW	2018/01/17	<MDL 0.04	50.0	No	No
Uranium: U (µg/L) - TW	2018/01/17	0.257	20.0	No	No
Fluoride: F (mg/L) - TW	2017/01/11	0.08	1.5	No	No
Nitrite (mg/L) - TW	2019/01/07	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW	2019/04/02	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW	2019/07/08	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW	2019/10/07	<MDL 0.003	1.0	No	No
Nitrate (mg/L) - TW	2019/01/07	0.011	10.0	No	No
Nitrate (mg/L) - TW	2019/04/02	<MDL 0.006	10.0	No	No
Nitrate (mg/L) - TW	2019/07/08	0.028	10.0	No	No
Nitrate (mg/L) - TW	2019/10/07	0.012	10.0	No	No
Sodium: Na (mg/L) - TW	2017/01/11	10.7	20*	No	Yes

Note: MDL = Minimum Detection Limit

\*There is no "MAC" for Sodium. The aesthetic objective is 200 mg/L. The local Medical Officer of Health should be notified when the sodium concentration exceeds 20 mg/L so that this information may be communicated to local physicians for their use with patients on sodium restricted diets.

**Table 5: Summary of lead testing under Schedule 15.1 during this reporting period**

Location Type	Number of Samples	Range of Lead Results		MAC	Number of Exceedances
		Minimum	Maximum		
Lead – Plumbing (µg/L)	Not Applicable - Relief from all Plumbing Requirements*				
Lead – Distribution** (µg/L)	Not Applicable for Reporting Period				

Note: *The Alkalinity results for 2019 were 218 and 220 mg/L as CaCO<sub>3</sub>.*

\*This system qualifies for the plumbing exemption as per O. Regulation 170/03 Schedule 15.1-5 (9) (10).

\*\*Distribution lead samples are taken every 36 months. The next set of distribution lead samples is scheduled for 2021.

**Table 6: Summary of Organic parameters sampled during this reporting period or the most recent sample results**

Parameter	Sample Date (yyyy/mm/dd)	Sample Result	Maximum Allowable Concentration (MAC)	Number of Exceedances	
				MAC	½ MAC
Alachlor (µg/L) - TW	2018/01/17	<MDL 0.02	5.0	No	No
Atrazine + N-dealkylated metabolites (µg/L) - TW	2018/01/17	<MDL 0.01	5.0	No	No
Azinphos-methyl (µg/L) - TW	2018/01/17	<MDL 0.05	20.0	No	No
Benzene (µg/L) - TW	2018/01/17	<MDL 0.32	1.0	No	No
Benzo(a)pyrene (µg/L) - TW	2018/01/17	<MDL 0.004	0.01	No	No
Bromoxynil (µg/L) - TW	2018/01/17	<MDL 0.33	5.0	No	No
Carbaryl (µg/L) - TW	2018/01/17	<MDL 0.05	90.0	No	No
Carbofuran (µg/L) - TW	2018/01/17	<MDL 0.01	90.0	No	No
Carbon Tetrachloride (µg/L) - TW	2018/01/17	<MDL 0.16	2.0	No	No
Chlorpyrifos (µg/L) - TW	2018/01/17	<MDL 0.02	90.0	No	No
Diazinon (µg/L) - TW	2018/01/17	<MDL 0.02	20.0	No	No
Dicamba (µg/L) - TW	2018/01/17	<MDL 0.2	120.0	No	No
1,2-Dichlorobenzene (µg/L) - TW	2018/01/17	<MDL 0.41	200.0	No	No
1,4-Dichlorobenzene (µg/L) - TW	2018/01/17	<MDL 0.36	5.0	No	No
1,2-Dichloroethane (µg/L) - TW	2018/01/17	<MDL 0.35	5.0	No	No
1,1-Dichloroethylene (µg/L) - TW	2018/01/17	<MDL 0.33	14.0	No	No
Dichloromethane (Methylene Chloride) (µg/L) - TW	2018/01/17	<MDL 0.35	50.0	No	No
2,4-Dichlorophenol (µg/L) - TW	2018/01/17	<MDL 0.15	900.0	No	No
2,4-Dichlorophenoxy acetic acid (2,4-D) (µg/L) - TW	2018/01/17	<MDL 0.19	100.0	No	No
Diclofop-methyl (µg/L) - TW	2018/01/17	<MDL 0.4	9.0	No	No
Dimethoate (µg/L) - TW	2018/01/17	<MDL 0.03	20.0	No	No
Diquat (µg/L) - TW	2018/01/17	<MDL 1.0	70.0	No	No
Diuron (µg/L) - TW	2018/01/17	<MDL 0.03	150.0	No	No
Glyphosate (µg/L) - TW	2018/01/17	<MDL 1.0	280.0	No	No
Malathion (µg/L) - TW	2018/01/17	<MDL 0.02	190.0	No	No
Metolachlor (µg/L) - TW	2018/01/17	<MDL 0.01	50.0	No	No
Metribuzin (µg/L) - TW	2018/01/17	<MDL 0.02	80.0	No	No

Parameter	Sample Date (yyyy/mm/dd)	Sample Result	Maximum Allowable Concentration (MAC)	Number of Exceedances	
				MAC	½ MAC
Monochlorobenzene (Chlorobenzene) (µg/L) - TW	2018/01/17	<MDL 0.3	80.0	No	No
Paraquat (µg/L) - TW	2018/01/17	<MDL 1.0	10.0	No	No
PCB (µg/L) - TW	2018/01/17	<MDL 0.04	3.0	No	No
Pentachlorophenol (µg/L) - TW	2018/01/17	<MDL 0.15	60.0	No	No
Phorate (µg/L) - TW	2018/01/17	<MDL 0.01	2.0	No	No
Picloram (µg/L) - TW	2018/01/17	<MDL 1.0	190.0	No	No
Prometryne (µg/L) - TW	2018/01/17	<MDL 0.03	1.0	No	No
Simazine (µg/L) - TW	2018/01/17	<MDL 0.01	10.0	No	No
Terbufos (µg/L) - TW	2018/01/17	<MDL 0.01	1.0	No	No
Tetrachloroethylene (µg/L) - TW	2018/01/17	<MDL 0.35	10.0	No	No
2,3,4,6-Tetrachlorophenol (µg/L) - TW	2018/01/17	<MDL 0.2	100.0	No	No
Triallate (µg/L) - TW	2018/01/17	<MDL 0.01	230.0	No	No
Trichloroethylene (µg/L) - TW	2018/01/17	<MDL 0.44	5.0	No	No
2,4,6-Trichlorophenol (µg/L) - TW	2018/01/17	<MDL 0.25	5.0	No	No
2-methyl-4-chlorophenoxyacetic acid (MCPA) (µg/L) - TW	2018/01/17	<MDL 0.12	100.0	No	No
Trifluralin (µg/L) - TW	2018/01/17	<MDL 0.02	45.0	No	No
Vinyl Chloride (µg/L) - TW	2018/01/17	<MDL 0.17	1.0	No	No
Trihalomethane: Total Annual Average (µg/L) - DW	4 Quarters of 2019	13.075	100.00	No	No
Haloacetic Acid: Total Annual Average (µg/L) - DW	4 Quarters of 2019	5.3	80.00	No	No

Note: MDL = Minimum Detection Limit

**Table 7: List of Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.**

Parameter	Result Value	Unit of Measure	Date of Sample
Sodium: Na - TW	10.7	mg/L	2017/01/11

Note: This table highlights the parameters with a "Yes" in the ½ MAC columns of Table 4 and Table 6.