

Raw Water Flowrate – Well #3 (CW3)		
Timeframe	Average Flowrate (L/sec)	Maximum Flowrate (L/sec)
July	6.62	5.99
August	6.76	6.81
September	0.00	0.00
October	0.00	0.00
November	0.00	0.00
December	3.58	14.53
2023	3.21	16.88

Note: Well #3 (CW3) was offline in September, November and October, 2023

A review of flow information for the reporting period indicates that Colgan Well 3 operated within the allowable flowrate in the PTTW maximum allowable raw water flowrate for Well #3 (CW3) for 2023:

- From January 1 to January 26, 2023: the system operated within the maximum allowable raw water flowrate for Well #3 (CW3) under PTTW #4352-AYULX7 (7.6 L/sec)
- From January 27 to December 31, 2023- the system operated within the maximum allowable raw water flowrate for Well #3 (CW3) under PTTW #4716-CMXNKC (12.4 L/sec) with the exception of January, March and December 2023 where flowrate exceedances were a result of well pump startups. Upon well start up, for the first 5 minutes well water is directed to waste prior to being directed to the treatment system. Singer valves are used to ensure that the flowrate to the treatment system is throttled to run between 5-6 L/sec. All daily flowrate averages were below the flow rate limit.

Table 11. Combined (CW1, CW2 and CW3) Raw Water Average and Maximum Flow Volume with Comparison to Rated Capacity in 2023

Date	Average Combined Taking (m³/day)	Percent of Allowable Volume (1,071.36 m³/day)	Maximum Combined Taking (m³/day)	Percent of Allowable Volume (1,071.36 m³/day)
January	61.26	5.72%	241.06	22.50%
February	70.11	6.54%	150.00	14.00%
March	137.07	12.79%	500.08	46.68%
April	112.00	10.45%	719.00	67.11%
May	129.34	12.07%	576.00	53.76%
June	78.86	7.36%	110.04	10.27%
July	53.17	4.96%	88.62	8.27%
August	108.24	10.10%	763.55	71.27%
September	72.31	6.75%	127.92	11.94%
October	81.98	7.65%	257.21	24.01%
November	162.76	15.19%	444.88	41.52%
December	357.24	33.34%	750.62	70.06%

Date	Average Combined Taking (m³/day)	Percent of Allowable Volume (1,071.36 m³/day)	Maximum Combined Taking (m³/day)	Percent of Allowable Volume (1,071.36 m³/day)
2023	119.23	11.13%	763.55	71.27%

A review of flow information for the reporting period indicates that the system operated within the PTTW's maximum allowable maximum raw combined (CW1, CW2, and CW3) allowable taking volume for 2023 (1,071.36 m³/day).

As per PTTW #4716-CMXNKC an average daily water taking is shall be assessed based on a 90-day rolling average from the wellfield - Source 1 (CW1), Source 2 (CW2) and Source 3 (CW3) and the 90-day rolling average shall not exceed 800,000 L/day (800 m³/day). Table 11 provides the average daily water taking as update on a daily basis, where flow data is averaged out each day inclusive of the current date and the 89 days preceding before it.

Table 11. Wellfield Combined (CW1, CW2 and CW3) Average Daily Water Taking-90-Day Rolling Average for 2023

Date (DD-MM-YYYY)	90- Day Rolling Average (m³/day)
01/01/2023	63.549
01/02/2023	63.567
01/03/2023	63.653
01/04/2023	63.675
01/05/2023	63.752
01/06/2023	63.755
01/07/2023	63.761
01/08/2023	63.858
01/09/2023	63.890
01/10/2023	63.960
01/11/2023	64.049
01/12/2023	64.117
01/13/2023	64.199
01/14/2023	64.286
01/15/2023	64.303
01/16/2023	64.451
01/17/2023	64.569
01/18/2023	64.739
01/19/2023	64.842
01/20/2023	64.926
01/21/2023	65.100

Date (DD-MM-YYYY)	90- Day Rolling Average (m³/day)
01/22/2023	65.217
01/23/2023	66.266
01/24/2023	66.267
01/25/2023	66.319
01/26/2023	66.181
01/27/2023	66.326
01/28/2023	66.385
01/29/2023	66.603
01/30/2023	68.516
01/31/2023	70.692
02/01/2023	71.933
02/02/2023	73.032
02/03/2023	73.410
02/04/2023	73.665
02/05/2023	73.967
02/06/2023	74.158
02/07/2023	74.306
02/08/2023	74.475
02/09/2023	74.640
02/10/2023	74.875
02/11/2023	75.057
02/12/2023	75.210
02/13/2023	75.462
02/14/2023	75.671
02/15/2023	75.850
02/16/2023	75.624
02/17/2023	76.199
02/18/2023	76.418
02/19/2023	76.727
02/20/2023	77.152
02/21/2023	77.493
02/22/2023	77.851
02/23/2023	78.024
02/24/2023	78.420
02/25/2023	78.718
02/26/2023	78.979
02/27/2023	79.246
02/28/2023	79.535
03/01/2023	79.549
03/02/2023	79.673

Date (DD-MM-YYYY)	90- Day Rolling Average (m³/day)
03/03/2023	79.901
03/04/2023	80.093
03/05/2023	78.673
03/06/2023	77.360
03/07/2023	75.568
03/08/2023	75.547
03/09/2023	75.969
03/10/2023	76.160
03/11/2023	76.369
03/12/2023	76.537
03/13/2023	74.654
03/14/2023	72.330
03/15/2023	72.538
03/16/2023	72.755
03/17/2023	73.551
03/18/2023	73.730
03/19/2023	72.792
03/20/2023	70.972
03/21/2023	72.691
03/22/2023	72.826
03/23/2023	74.080
03/24/2023	76.191
03/25/2023	76.596
03/26/2023	76.937
03/27/2023	78.307
03/28/2023	81.244
03/29/2023	86.057
03/30/2023	90.210
03/31/2023	90.124
04/01/2023	90.460
04/02/2023	90.948
04/03/2023	92.368
04/04/2023	96.176
04/05/2023	96.469
04/06/2023	96.768
04/07/2023	97.173
04/08/2023	97.472
04/09/2023	97.659
04/10/2023	97.907
04/11/2023	98.219

Date (DD-MM-YYYY)	90- Day Rolling Average (m³/day)
04/12/2023	98.512
04/13/2023	98.812
04/14/2023	98.863
04/15/2023	99.140
04/16/2023	99.396
04/17/2023	99.597
04/18/2023	99.821
04/19/2023	100.047
04/20/2023	100.408
04/21/2023	100.788
04/22/2023	101.005
04/23/2023	107.534
04/24/2023	107.807
04/25/2023	108.611
04/26/2023	108.994
04/27/2023	110.168
04/28/2023	110.298
04/29/2023	110.489
04/30/2023	109.035
05/01/2023	107.183
05/02/2023	106.407
05/03/2023	108.569
05/04/2023	111.212
05/05/2023	113.329
05/06/2023	119.009
05/07/2023	121.454
05/08/2023	121.677
05/09/2023	121.888
05/10/2023	122.378
05/11/2023	121.753
05/12/2023	122.333
05/13/2023	122.448
05/14/2023	122.631
05/15/2023	124.271
05/16/2023	126.754
05/17/2023	127.281
05/18/2023	126.959
05/19/2023	126.954
05/20/2023	126.739
05/21/2023	126.490

Date (DD-MM-YYYY)	90- Day Rolling Average (m³/day)
05/22/2023	126.490
05/23/2023	126.099
05/24/2023	126.348
05/25/2023	125.970
05/26/2023	126.190
05/27/2023	126.374
05/28/2023	126.590
05/29/2023	126.830
05/30/2023	125.998
05/31/2023	124.526
06/01/2023	124.984
06/02/2023	125.439
06/03/2023	125.470
06/04/2023	125.613
06/05/2023	125.878
06/06/2023	126.221
06/07/2023	126.133
06/08/2023	126.131
06/09/2023	126.343
06/10/2023	126.448
06/11/2023	126.362
06/12/2023	126.305
06/13/2023	124.669
06/14/2023	123.024
06/15/2023	122.595
06/16/2023	122.666
06/17/2023	122.844
06/18/2023	123.197
06/19/2023	122.038
06/20/2023	122.318
06/21/2023	121.608
06/22/2023	119.748
06/23/2023	119.682
06/24/2023	119.955
06/25/2023	118.978
06/26/2023	116.045
06/27/2023	111.529
06/28/2023	107.300
06/29/2023	107.511
06/30/2023	107.320

Date (DD-MM-YYYY)	90- Day Rolling Average (m³/day)
07/01/2023	107.018
07/02/2023	105.791
07/03/2023	102.251
07/04/2023	102.127
07/05/2023	102.040
07/06/2023	101.790
07/07/2023	101.562
07/08/2023	101.353
07/09/2023	101.074
07/10/2023	100.863
07/11/2023	100.649
07/12/2023	100.346
07/13/2023	100.263
07/14/2023	100.025
07/15/2023	99.876
07/16/2023	99.604
07/17/2023	99.271
07/18/2023	99.044
07/19/2023	98.091
07/20/2023	98.081
07/21/2023	97.710
07/22/2023	90.175
07/23/2023	89.983
07/24/2023	88.918
07/25/2023	88.708
07/26/2023	87.478
07/27/2023	87.540
07/28/2023	87.745
07/29/2023	87.780
07/30/2023	87.830
07/31/2023	87.434
08/01/2023	84.280
08/02/2023	81.243
08/03/2023	78.808
08/04/2023	72.983
08/05/2023	70.363
08/06/2023	70.167
08/07/2023	69.905
08/08/2023	69.602
08/09/2023	70.206

Date (DD-MM-YYYY)	90- Day Rolling Average (m³/day)
08/10/2023	70.916
08/11/2023	70.679
08/12/2023	70.467
08/13/2023	68.861
08/14/2023	66.291
08/15/2023	66.282
08/16/2023	66.250
08/17/2023	66.296
08/18/2023	66.330
08/19/2023	66.330
08/20/2023	66.343
08/21/2023	66.679
08/22/2023	66.618
08/23/2023	66.904
08/24/2023	66.418
08/25/2023	68.446
08/26/2023	75.962
08/27/2023	80.952
08/28/2023	81.087
08/29/2023	80.465
08/30/2023	79.868
08/31/2023	79.519
09/01/2023	79.511
09/02/2023	79.588
09/03/2023	79.273
09/04/2023	78.862
09/05/2023	79.005
09/06/2023	78.895
09/07/2023	78.772
09/08/2023	79.401
09/09/2023	79.445
09/10/2023	79.572
09/11/2023	79.685
09/12/2023	79.690
09/13/2023	79.672
09/14/2023	79.761
09/15/2023	79.434
09/16/2023	79.231
09/17/2023	78.770
09/18/2023	78.644

Date (DD-MM-YYYY)	90- Day Rolling Average (m³/day)
09/19/2023	78.388
09/20/2023	78.402
09/21/2023	78.566
09/22/2023	78.399
09/23/2023	78.427
09/24/2023	78.553
09/25/2023	78.225
09/26/2023	78.485
09/27/2023	78.405
09/28/2023	78.289
09/29/2023	78.388
09/30/2023	78.388
10/01/2023	78.421
10/02/2023	78.624
10/03/2023	78.844
10/04/2023	78.871
10/05/2023	78.988
10/06/2023	79.278
10/07/2023	79.631
10/08/2023	80.119
10/09/2023	80.806
10/10/2023	81.359
10/11/2023	81.413
10/12/2023	81.431
10/13/2023	81.588
10/14/2023	81.789
10/15/2023	81.987
10/16/2023	82.212
10/17/2023	82.905
10/18/2023	82.551
10/19/2023	82.898
10/20/2023	83.016
10/21/2023	83.041
10/22/2023	83.554
10/23/2023	83.599
10/24/2023	83.680
10/25/2023	83.642
10/26/2023	83.453
10/27/2023	84.048
10/28/2023	83.820

Date (DD-MM-YYYY)	90- Day Rolling Average (m³/day)
10/29/2023	84.263
10/30/2023	86.262
10/31/2023	88.721
11/01/2023	90.007
11/02/2023	91.997
11/03/2023	93.911
11/04/2023	96.418
11/05/2023	96.729
11/06/2023	96.548
11/07/2023	96.715
11/08/2023	95.480
11/09/2023	95.634
11/10/2023	95.768
11/11/2023	95.975
11/12/2023	95.986
11/13/2023	96.072
11/14/2023	96.117
11/15/2023	95.977
11/16/2023	97.661
11/17/2023	99.972
11/18/2023	100.262
11/19/2023	100.567
11/20/2023	101.080
11/21/2023	102.008
11/22/2023	102.827
11/23/2023	102.658
11/24/2023	99.077
11/25/2023	98.049
11/26/2023	101.793
11/27/2023	103.754
11/28/2023	104.657
11/29/2023	105.429
11/30/2023	105.764
12/01/2023	107.600
12/02/2023	112.165
12/03/2023	115.961
12/04/2023	119.904
12/05/2023	121.747
12/06/2023	125.754
12/07/2023	129.131

Date (DD-MM-YYYY)	90- Day Rolling Average (m³/day)
12/08/2023	131.353
12/09/2023	133.940
12/10/2023	134.725
12/11/2023	135.843
12/12/2023	138.792
12/13/2023	142.306
12/14/2023	144.883
12/15/2023	150.554
12/16/2023	154.486
12/17/2023	155.250
12/18/2023	158.296
12/19/2023	161.404
12/20/2023	164.307
12/21/2023	166.779
12/22/2023	167.472
12/23/2023	168.853
12/24/2023	170.848
12/25/2023	173.084
12/26/2023	179.998
12/27/2023	187.455
12/28/2023	195.079
12/29/2023	200.508
12/30/2023	203.727
12/31/2023	203.932

A review of the above information indicates that at no point in 2023 did the system exceed the PTTW's 90-day average daily water taking limit (800 m³/day) from the wellfield- Source 1 (CW1), Source 2 (CW2) and Source 3 (CW3).